ELAND[®] CABLES

BS 6724 Copper Conductor Multi Core SWA 1.9/3.3kV Cable



ELAND GABLES G

Eland Product Group: B9L

APPLICATION

Power and auxiliary control cables for use in power networks, underground, outdoor and indoor applications and for use in cable ducting. For installation where fire, smoke emission and toxic fumes create a potential threat to life and equipment.

CHARACTERISTICS

Voltage Rating Uo/U 1.9/3.3kV

Temperature Rating Maximum Operating: +90°C Maximum Short-Circuit: +250°C

Minimum Bending Radius 12 x overall diameter

CONSTRUCTION

Conductor Class 2 stranded copper

Insulation XLPE (Cross-Linked Polyethylene)

Filler HFFR (Halogen free flame retardant)

Armour SWA (Galvanised Steel Wire Armour)

Outer Sheath HFFR (Halogen free flame retardant)

Core Identification ● Brown ● Black ● Grey

Sheath Colour Black

STANDARDS

BS 6724, IEC/EN 60228, IEC/EN 60502-1

Low Smoke Zero Halogen according to IEC/EN 61034, IEC/EN 60754 Flame retardant according to EN / IEC 60332-1

THE CABLE LAB® AN ISO/IEC 17025 AND IECEE CBTL ACCREDITED FACILITY

Our world-class testing facility assures the quality and compliance of this cable through a continuous and rigorous testing regime.



SUSTAINABILITY COMMITMENT



We are on a journey to Net Zero. We've committed to the Science Based Targets Initiative and we're a signatory to the United Nations Global Compact SDGs.

SILVER 2022 ecovadis Sustainability Rating Learn more about our carbon emissions reduction actions, comprehensive recycling services, and wider ESG activities for sustainable operations at:

www.elandcables.com/company/about-us/esg-sustainability

REGULATORY COMPLIANCE

This cable is compliant with European Regulation EN 50575, the Construction Products Regulation.

* CPR * * COMPLIANT * * EN 50575 *

This cable meets the requirements of the Low Voltage Directive 2014/35/EU and the RoHS Directive 2011/65/EU. RoHS compliance has been tested and confirmed by The Cable Lab[®] as meeting the requirements of the BSI RoHS Trusted Kitemark[™].



DIMENSIONS

ELAND PART NO.	NO. OF CORES	NOMINAL CROSS SECTIONAL AREA mm ²	NOMINAL DIAMETER OF CONDUCTOR mm	NOMINAL THICKNESS OF INSULATION mm	MINMUM THICKNESS OF OUTER SHEATH mm	NOMINAL OUTER DIAMETER mm	NOMINAL WEIGHT kg/km
B9L03010BK	3	10	3.85	2.0	1.24	23	1545
B9L03016BK	3	16	4.70	2.0	1.24	27	1680
B9L03025BK	3	25	5.85	2.0	1.24	30	2100
B9L03035BK	3	35	6.90	2.0	1.32	32	2530

ELECTRICAL CHARACTERISTICS

NOMINAL CROSS SECTIONAL AREA		MAXIMUM CONDUCTOR DC RESISTANCE AT 20°C			
mm ²	Clipped direct	In free air or on a perforated cable tray etc, horizontal or vertical at 30°C	Direct in ground or in ducting in ground, in or around buildings at 20°C	Ω/km	
	1 three or 1 four core cable, three- phase a.c or d.c	1 three or 1 four core cable, three- phase a.c or d.c	1 three or 1 four core cable, three- phase a.c or d.c		
10	73	78	58	1.83	
16	94	99	75	1.15	
25	124	131	96	0.727	
35	154	162	115	0.524	

Air ambient temperature: 30°C Ground ambient temperature: 20°C Conductor operating temperature: 90°C

Notes

1. Where a conductor operates at a temperature exceeding 70°C it must be ascertained that the equipment connected to the conductor is suitable for the conductor operating temperature (see Regulation 512.1.2 of the 18th Edition of IEE Wiring Regulations).

2. Where cables in this table are connected to equipment or accessories designed to operate at a temperature not exceeding 70°C, the current ratings given in the equivalent table for 70°C thermoplastic insulated cables (Table 4D4A) must be used (see also Regulation 523.1 of the 18th Edition of IEE Wiring Regulations).

The above table is in accordance with Table 4E4A of the 18th Edition of IEE Wiring Regulations BS7671 and IEC 60364-5-52

The information contained within this datasheet is for guidance only and is subject to change without notice or liability. All the information is provided in good faith and is believed to be correct at the time of publication. When selecting cable accessories, please note that actual cable dimensions may vary due to manufacturing tolerances.